

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units			Action Taken
COLUMBUS 1A	1/11/2024 07:17	1/18/2024 10:38	70284326001	Lead	<1.0	5	ug/L			
COLUMBUS 16	1/11/2024 07:18	1/18/2024 10:43	70284326002	Lead	<1.0	5	ug/L			
COLUMBUS 13	1/11/2024 07:20	1/18/2024 10:44	70284326003	Lead	14.2	5	ug/L	Room 177	Classroom Sink	Posted Sign
COLUMBUS 14	1/11/2024 07:22	1/18/2024 10:46	70284326004	Lead	32.1	5	ug/L	Room 168	Classroom Sink	Posted Sign
COLUMBUS 15	1/11/2024 07:24	1/18/2024 10:47	70284326005	Lead	12.4	5	ug/L	Room 166	Classroom Sink	Posted Sign
COLUMBUS 16	1/11/2024 07:21	1/18/2024 10:49	70284326006	Lead	10.0	5	ug/L	Room 171	Classroom Sink	Posted Sign
COLUMBUS 17	1/11/2024 07:23	1/18/2024 10:11	70284326007	Lead	2.8	5	ug/L			
COLUMBUS 18	1/11/2024 07:27	1/18/2024 10:12	70284326008	Lead	<1.0	5	ug/L			
COLUMBUS 19	1/11/2024 07:25	1/18/2024 10:53	70284326009	Lead	13.8	5	ug/L	Room 167	Classroom Sink	Posted Sign
COLUMBUS 22	1/11/2024 07:30	1/18/2024 10:55	70284326010	Lead	<1.0	5	ug/L			
COLUMBUS 24	1/11/2024 07:34	1/18/2024 10:57	70284326011	Lead	<1.0	5	ug/L			
COLUMBUS 25	1/11/2024 07:39	1/18/2024 10:58	70284326012	Lead	<1.0	5	ug/L			
COLUMBUS 27	1/11/2024 07:36	1/18/2024 11:00	70284326013	Lead	1.1	5	ug/L			
COLUMBUS 28	1/11/2024 07:37	1/18/2024 11:01	70284326014	Lead	1.1	5	ug/L			
COLUMBUS 29	1/11/2024 07:38	1/18/2024 11:03	70284326015	Lead	1.1	5	ug/L			
COLUMBUS 39	1/11/2024 06:58	1/18/2024 11:04	70284326016	Lead	<1.0	5	ug/L			
COLUMBUS 41	1/11/2024 06:49	1/18/2024 11:06	70284326017	Lead	11.3	5	ug/L	Room 117	Classroom Sink	Posted Sign
COLUMBUS 44	1/11/2024 06:54	1/18/2024 11:07	70284326018	Lead	<1.0	5	ug/L			
COLUMBUS 45	1/11/2024 06:50	1/18/2024 11:12	70284326019	Lead	10.2	5	ug/L	Room 116	Classroom Sink	Posted Sign
COLUMBUS 46	1/11/2024 06:55	1/18/2024 11:13	70284326020	Lead	2.4	5	ug/L			
COLUMBUS 47	1/11/2024 06:51	1/18/2024 11:15	70284326021	Lead	6.7	5	ug/L	Room 116	Classroom Sink	Posted Sign
COLUMBUS 48	1/11/2024 06:57	1/18/2024 11:20	70284326022	Lead	34.9	5	ug/L	Room 114	Classroom Sink	Posted Sign
COLUMBUS 62	1/11/2024 07:04	1/18/2024 11:32	70284326023	Lead	7.7	5	ug/L	Room 112	Classroom Sink	Posted Sign
COLUMBUS 66	1/11/2024 07:05	1/18/2024 11:35	70284326024	Lead	20.8	5	ug/L	Room 104a	Classroom Sink	Posted Sign
COLUMBUS 70	1/11/2024 07:07	1/18/2024 11:38	70284326025	Lead	<1.0	5	ug/L			
COLUMBUS 71	1/11/2024 07:06	1/18/2024 11:41	70284326026	Lead	1.4	5	ug/L			
COLUMBUS 72	1/11/2024 07:09	1/18/2024 11:44	70284326027	Lead	<1.0	5	ug/L			
COLUMBUS 74	1/11/2024 07:10	1/18/2024 11:50	70284326028	Lead	<1.0	5	ug/L			
COLUMBUS 75	1/11/2024 07:11	1/18/2024 11:53	70284326029	Lead	1.7	5	ug/L			
COLUMBUS 77	1/11/2024 07:14	1/18/2024 11:56	70284326030	Lead	<1.0	5	ug/L			
COLUMBUS 78	1/11/2024 07:15	1/18/2024 15:14	70284326031	Lead	5.0	5	ug/L			
COLUMBUS 79	1/11/2024 07:31	1/18/2024 15:19	70284326032	Lead	25.7	5	ug/L	Room 158	Classroom Sink	Posted Sign
COLUMBUS 80	1/11/2024 07:32	1/18/2024 15:23	70284326033	Lead	13.1	5	ug/L	Room 185	Classroom Sink	Posted Sign
COLUMBUS 86 RM 118 CAFE KIT.SI	1/11/2024 06:45	1/18/2024 15:31	70284326034	Lead	<1.0	5	ug/L			
COLUMBUS 87 RM 118 CAFE KIT.SI	1/11/2024 06:46	1/18/2024 15:32	70284326035	Lead	<1.0	5	ug/L			
COLUMBUS 88 RM 118 CAFE KIT.SI	1/11/2024 06:47	1/18/2024 15:34	70284326036	Lead	<1.0	5	ug/L			
COLUMBUS 89 RM 113	1/11/2024 07:01	1/18/2024 15:36	70284326037	Lead	7.4	5	ug/L	Room 113	Classroom Sink	Posted Sign
COLUMBUS 90 DF ACROSS 122	1/11/2024 07:42	1/18/2024 15:37	70284326038	Lead	<1.0	5	ug/L			

NYSDOH Action Level for Lead In Schools of 5 ppb