

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units		
CONKLING 1	1/12/2024 05:10	1/19/2024 13:09	70284325001	Lead	3.1	5	ug/L		
CONKLING 2	1/12/2024 05:11	1/19/2024 13:14	70284325002	Lead	1.4	5	ug/L		
CONKLING 3	1/12/2024 05:12	1/19/2024 13:15	70284325003	Lead	<1.0	5	ug/L		
CONKLING 7	1/12/2024 05:09	1/19/2024 13:17	70284325004	Lead	<1.0	5	ug/L		
CONKLING 14 126 HALL DF	1/12/2024 05:14	1/19/2024 13:18	70284325005	Lead	<1.0	5	ug/L		
CONKLING 21 222 HALL DF	1/12/2024 05:16	1/19/2024 13:20	70284325006	Lead	<1.0	5	ug/L		
CONKLING 33	1/12/2024 05:21	1/19/2024 13:24	70284325007	Lead	<1.0	5	ug/L		
CONKLING 47 311 HALL DF	1/12/2024 05:23	1/19/2024 13:26	70284325008	Lead	<1.0	5	ug/L		
CONKLING 52	1/12/2024 05:25	1/18/2024 16:07	70284325009	Lead	107	5	ug/L	Art Room	Sink 1
CONKLING 53	1/12/2024 05:26	1/19/2024 13:27	70284325010	Lead	9.5	5	ug/L	Art Room	Sink 2
CONKLING 54	1/12/2024 05:27	1/19/2024 13:29	70284325011	Lead	15.8	5	ug/L	Art Room	Sink 3

Action Taken

Posted Sign

Posted Sign

Posted Sign

NYSDOH Action Level for Lead in Schools of 5 ppb